

**SIMA LABS PVT. LTD.****Sophisticated Industrial Materials
Analytic Labs Pvt. Ltd.**

(GOVT. APPROVED TESTING LABORATORIES)

A-3/7, Mayapuri Industrial Area, Ph- II, New Delhi - 110064

Phone : +(91)-(11) 43854300

Email : reports@simalab.com

CIN No : U74899DL1988PTC031785

Website : www.simalab.net | www.simalab.com

ISO 9001:2015 • ISO 14001:2015 • OHSAS 18001:2007 • NABL ACCREDITED • FSSAI, AGMARK, BIS, AYUSH & MoEF RECOGNISED

7.8 F-01

**TEST REPORT**

PARTY CODE : S/JK/13738

ST. JOSEPH'S COMMUNITY HOSPITAL

BARJANI TALAB, SMAILPUR, SAMBA-181133 J&K

REPORT NO. : SN0529002319

REF. NO. : NS

REF. DATE : NS

DT.RECD : 29/05/2019



SAMPLE NAME : EFFLUENT WATER (STP-INLET)

RESULTS OF ANALYSIS

Reference : EP Act Standard

DESCRIPTION : One effluent water sample from inlet of STP was collected by us on 28/05/2019

SAMPLING DATE : 28/05/2019

SAMPLE QTY. : 1 LTR.

S.No.	Parameters	Units	Results	Protocols
1.	pH	NA	6.92	IS:3025 (P-11)
2.	Total Suspended Solids	mg/L	130	IS:3025 (P-17)
3.	Chemical Oxygen Demand	mg/L	423	IS:3025 (P-58)
4.	Biochemical Oxygen Demand (for 3 days at 27 Deg C)	mg/L	210	IS:3025 (P-44)
5.	Oil & Grease	mg/L	5.2	IS:3025 (P-39)
6.	Phosphate (as P)	mg/L	4.8	IS:3025 (P-31)

Date of performance : 29/05/2019 to 03/06/2019

NA-Not Applicable

SAMPLE COLLECTED BY US

DATE : 03/06/2019

AUTHORISED SIGNATORY

REMARKS 1. Results listed refer only to the tested sample & applicable parameters. Endorsement of products is neither inferred nor implied. Page : 1 of 1
2. Liability of laboratory is limited to the invoiced amount only. Any dispute arising out of this report shall be subject to Delhi jurisdiction only.
3. This Report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of law and should not be used in any advertising media without special permission in writing.
4. Sample shall be disposed off after issue of Test Report unless specified.
5. A complaint register is available with the laboratory.

Rohit

HARIDWAR LABORATORY : Plot No. 37, Sector - 7, I.I.E SIIDCUL, Haridwar - 249403
BUILDING MATERIAL LAB : Plot No. 107/11/2 & 107/20, Udhog Nagar Indl Area, Mundka,
New Delhi-110041

Phone : +(91)-(01334)-235552
Phone : +(91)-93198-28884

Email : simaharidwar@simalab.co.in
Email : bmlab@simalab.com

THIS CERTIFICATE IS NOT VALID WITHOUT A HOLOGRAM**SIMA**